

Water Pollution Control Authority
Public Hearing Meeting Minutes
August 5, 2014

The Town of East Hampton Water Pollution Control Authority held a Public Hearing at 5:00 P.M. on Tuesday, August 5, 2014 at the Town of Colchester--Town of East Hampton Wastewater Treatment Plant, 20 Gildersleeve Drive, East Hampton, CT. The following members were in attendance:

Mark Barmasse, Chairman
Ralph Nesci

David Kelsey
John Suprono

Daniel Valentine was not in attendance. Vincent F. Susco, Jr., Public Utilities Administrator, Stephen Motto, Edgewater Hill, LLC and Ted Turner were in attendance.

Call to Order

Chairman Barmasse called the Public Hearing to order to accept public comment on the proposed wastewater extension known as "Edgewater Hill, a Mixed Use Development District" at 5:25 P. M. He read the Public Hearing notice, which is attached and made a part of the minutes.

Public Comment of the proposed sewer extension known as Edgewater Hill

Mr. Barmasse introduced Mr. Motto who presented an overview of the project and the proposed wastewater system. He explained that the wastewater system for this project will be entirely gravity sewer lines and that this phase will include 7 commercial and 5 residential buildings. This system will connect to the existing manhole located in East High Street. From there the waste will flow west to the East High Street Lift Station that was upgraded in 2008.

Mr. Motto responded to several questions from the members. He indicated approvals for the project have been received and expects construction to begin shortly.

At this time Chairman Barmasse opened the meeting to public comment. There being no comments from the public, Chairman Barmasse called for the meeting to be closed.

Mr. Suprono motioned, seconded by Mr. Kelsey to close the meeting. All voting in favor.

Adjournment

The public hearing was closed at 5:35 P.M.

Respectfully submitted,



Vincent F. Susco, Jr.
Recording Secretary

Approved by unanimous vote of the Water Pollution Control Authority on October 7, 2014.