

**From:** [Jim Karrenberg](mailto:Jim.Karrenberg@chathamhealth.org)  
**To:** [frankcmagnottape@aol.com](mailto:frankcmagnottape@aol.com); [tclausi@opticom-ct.com](mailto:tclausi@opticom-ct.com)  
**Cc:** [DeCarli, Jeremy](mailto:DeCarli.Jeremy@easthamptonct.gov); [pbztech](mailto:pbztech@easthamptonct.gov)  
**Subject:** Review of Resubdivision Map for Carrie Sue Clauso Assessor's Parcel: 27/54/7 Tartia Road and Town Farm Road East Hampton as prepared by Frank Magnotta, P.E. Revision Date 5-18-22  
**Date:** Thursday, May 19, 2022 9:03:39 AM

---

**CAUTION:**

This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe. Remember to hover over any links and if you suspect the email is not legitimate or a phishing email, please contact Tom McMahon at x3363.

**Hello Frank and Tom,**

**The following is a list of comments and observations on the above subject matter:**

**1. Lot 7-3:**

- a. The location of the proposed Well and Subsurface Sewage Disposal System are in compliance with the Connecticut Public Health Code Section 19-13-B51d and 19-13-B103d (d) respectfully;**

**If I can be of assistance, I can be reached at [jim.karrenberg@chathamhealth.org](mailto:jim.karrenberg@chathamhealth.org) or by phone at 860-365-0884 Ext. 106.**

**Sincerely,**

**James G. Karrenberg, R.S.  
Chatham Health District**

---

**From:** Jim Karrenberg  
**Sent:** Thursday, May 5, 2022 3:19 PM  
**To:** [frankcmagnottape@aol.com](mailto:frankcmagnottape@aol.com) <[frankcmagnottape@aol.com](mailto:frankcmagnottape@aol.com)>; [tclausi@opticom-ct.com](mailto:tclausi@opticom-ct.com) <[tclausi@opticom-ct.com](mailto:tclausi@opticom-ct.com)>  
**Cc:** [DeCarli, Jeremy](mailto:DeCarli.Jeremy@easthamptonct.gov) <[jdecarli@easthamptonct.gov](mailto:jdecarli@easthamptonct.gov)>; [Doreen Stanulonis](mailto:Doreen.Stanulonis@easthamptonct.gov) <[pbztech@easthamptonct.gov](mailto:pbztech@easthamptonct.gov)>  
**Subject:** Review of Resubdivision Map for Carrie Sue Clauso Assessor's Parcel: 27/54/7 Tartia Road and Town Farm Road East Hampton as prepared by Frank Magnotta, P.E.Dated April 19, 2022

**Hello Frank and Tom,**

**The following is a list of comments and observations on the above subject matter:**

**1. Lot 7-2:**

- a. The location of the proposed Well and Subsurface Sewage Disposal System are in compliance with the Connecticut Public Health Code Section 19-13-B51d and 19-13-B103d (d) respectfully;**

**2. Lot 7-3:**

- a. On Sheet 3 of 4, the Lower Primary Trench needs to be adjusted so that is**

**is 10' or greater from the West End of TP 'A' with Ledge at 24" as noted in the Site Investigation Report Dated February 17, 2022 under Test Pit Comments;**

**b. Under Basis of Design Sheet 3 of 4, Design Percolation Rate needs to be noted as 10.1-20.0 min/in, not the noted 10 min/in.**

**If I can be of assistance, I can be reached at [jim.karrenberg@chathamhealth.org](mailto:jim.karrenberg@chathamhealth.org) or by phone at 860-365-0884 Ext. 106.**

**Sincerely,**

**James G. Karrenberg, R.S.  
Chatham Health District**

This electronic message is a public record as defined by the Connecticut Freedom of Information Act Section 1-200(5). A copy of this message and any reply will be retained by the Town of East Hampton and will be accessible to the public unless exempted by law.