

----- Forwarded Message -----

From: Steve Knauf <steve.knauf@chathamhealth.org>
To: dutchassociates@sbcglobal.net <dutchassociates@sbcglobal.net>
Sent: Thursday, January 30, 2020, 5:47:27 PM EST
Subject: Fw: 49 Oakum Dock Road

see below

Steve Knauf RS
Chief Sanitarian
Chatham Health District
860-228-5971 ext 140
860-228-5980 fax

From: Clark, Amanda <Amanda.Clark@ct.gov>
Sent: Thursday, January 30, 2020 2:36 PM
To: Steve Knauf <steve.knauf@chathamhealth.org>
Cc: Scully, Robert <Robert.Scully@ct.gov>
Subject: 49 Oakum Dock Road

Hi Steve,

Yesterday, 2 copies of the 2-bedroom system as-built for 33 Oakum Dock Rd. were dropped off to me and I'm not sure why.

As discussed, the 49 Oakum Dock plan received on January 14 for state review and approval needs to reflect the actual locations of sited structures. The 2 page plan revised through 8/12/19 does not reflect the most accurate information. Page 1 still shows a lot line between the properties. Page 2 shows proposed locations for the newly installed system instead of the actual. The well arc for the well we discussed is still missing and a note is needed indicating that it will be abandoned. Also, the type of geo wells (open or closed) installed needs to be included with the separating distance arc. The leaching system cross-section needs to show the additional cover required for H-20 loading. The pump detail needs to show the dual alternating pumps. I recommend re-reviewing the plan and submitting the design engineer theses and any additional comments you have.

Once I receive an updated plan addressing all of the above, I can start my review.

Thanks,
Amanda

Amanda J. Clark, RS
Environmental Analyst 3
Environmental Engineering Program
Connecticut Department of Public Health
410 Capitol Avenue, MS #12SEW
P.O. Box 340308
Hartford, CT 06134-0308

Phone: 860-509-7368
Fax: 860-509-7295
E-mail: amanda.clark@ct.gov
Website: <http://www.ct.gov/dph/subsurfacesewage>
Let us know how we are doing: [Survey](#)

Castonguay, Christine

From: DeCarli, Jeremy
Sent: Monday, February 03, 2020 10:01 AM
To: Castonguay, Christine
Subject: FW: 49 Oakum Dock Road

Please see below and put into the commission packets.

Jeremy

Jeremy DeCarli, AICP
Planning & Zoning Official
Town of East Hampton
T: 860-267-7450
E: jdecarli@easthamptonct.gov
www.easthamptonct.gov

M, W, Th: 8:00AM – 3:00pm
T: 8:00AM – 6:30PM
F: 8:00AM – 12:00PM

From: Charles Dutch <dutchassociates@sbcglobal.net>
Sent: Monday, February 3, 2020 8:38 AM
To: DeCarli, Jeremy <jdecarli@easthamptonct.gov>
Subject: Fw: 49 Oakum Dock Road

CAUTION:

This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe. Remember to hover over any links and if you suspect the email is not legitimate or a phishing email, please contact Tom McMahon at x363.

Mr. DeCarli-

Below is an email we received from Steve Knauf of Chatum Health Thursday evening. It is a forward of an email he received from Amanda Clark of CT Public Health. The email outlines what changes she is requesting in order to review the site plan for 49 Oakum Dock Rd.. The changes are relatively minor with regard to design changes and drafting. Charlie intends to have the revised plans with him for Wednesday's meeting. He will be calling shortly to discuss. Thank you.

Chris

Dutch & Associates
P.O. Box 163
392 South Main St. Colchester, CT 06415
Phone: (860)537-3465
Fax: (860)537-3466
<http://www.dutchassociates.com>